

FI-VE Isolanti S.r.l.
Via dell' Industria 21
Vittorio Veneto TV
ITALY

Eurofins Product Testing A/S
Smedeskovvej 38
8464 Galten
Denmark

CustomerSupport@eurofins.com
www.eurofins.com/VOC-testing

VOC EMISSION TEST REPORT

Indoor Air Comfort®


11 February 2020

1 Sample Information

Sample name	PIR VELO VETRO
Batch no.	-
Production date	14/10/2019
Product type	PU foam
Thickness, mm	100
Sample reception	24/10/2019

The tested sample PIR VELO VETRO has been selected by the customer as being representative for the product range of PIR VELOVETRO and PIR CAP8 which according to the information of the manufacturer are based on the overall same chemical composition, but with possible differences in thicknesses. The tested product PIR VELO VETRO is considered to be the "worst-case"-product regarding VOC emissions. *

2 Brief Evaluation of the Results

Regulation or protocol	Conclusion	Version of regulation or protocol
French VOC Regulation		Regulation of March and May 2011 (DEVL1101903D and DEVL1104875A)
French CMR components	Pass	Regulation of April and May 2009 (DEVP0908633A and DEVP0910046A)
ABG	Pass	Anforderungen an bauliche Anlagen bezüglich des Gesundheitsschutzes (ABG), Entwurf 31.08.2017/August 2018 (AgBB)
Belgian Regulation	Pass	Royal decree of May 2015 (C-2014/24239)
Indoor Air Comfort®	Pass	Indoor Air Comfort 6.0 of February 2017

Full details based on the testing and direct comparison with limit values are available in the following pages


Malene Laugesen
Analytical Service Manager


Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry

The results are only valid for the tested sample(s).

This report may only be copied or reprinted in its entity, parts of it only with a written acceptance by Eurofins.